

Kitemark™ Certificate

This is to certify that:

National Factory for Security and Safety
Equipment LLC (AMANCO)
P.O. Box. PC 124
Road No. 19
Rusayl Industrial Estate
Muscat
Oman

Holds Certificate Number:

KM 602638

In respect of:

BS EN 3
Portable fire extinguishers

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:



Chris Lewis - Certification Director, Product Certification

First Issued: 2014-01-14

Latest Issue: 2018-02-06

Effective Date: 2018-02-06

Expiry Date: 2019-02-05

Page: 1 of 2



003

...making excellence a habit.™

Kitemark™ Certificate

No. KM 602638

Model No	Description
ADSP1	1 kg ABC powder, stored pressure. Fire rating 8A & 55B
ADSP2	2 kg ABC powder, stored pressure. Fire rating 13A & 89B
ADSP4	4 kg ABC powder, stored pressure. Fire rating 27A & 183B
ADSP6	6 kg ABC powder, stored pressure. Fire rating 43A & 233B
ADSP6A	6 kg ABC powder, stored pressure. Fire rating 55A & 233B
ADSP6B	6 kg ABC powder, stored pressure. Fire rating 55A & 233B
ADSP9	9 kg ABC powder, stored pressure. Fire rating 55A & 233B
AFSP6A	6 litre foam (AFFF), stored pressure. Fire rating 27A & 183B
AFSP6B	6 litre foam (AFFF), stored pressure. Fire rating 13A & 183B
AFSP9A	9 litre foam (AFFF), stored pressure. Fire rating 34A & 233B
AFSP9B	9 litre foam (AFFF), stored pressure. Fire rating 21A & 233B
AWSP6A	6 litre water + additive, stored pressure. Fire rating 34A
AWSP6B	6 litre water, stored pressure. Fire rating 13A
AWSP9	9 litre water, stored pressure. Fire rating 21A
AC2	2 kg carbon dioxide. Fire rating 34B
AC5	5 kg carbon dioxide. Fire rating 89B
ASPK-6	6 litre wet chemical, stored pressure. Fire rating 13A and 75F

All the above products are certified to BS EN 3-7:2004+A1:2007

First Issued: 2014-01-14
Latest Issue: 2018-02-06

Effective Date: 2018-02-06
Expiry Date: 2019-02-05

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.